

QM-0705-042

# CERTIFICATE OF CONFORMITY



PSB Product Listing Scheme\*: **Class 2**

This Certificate is issued to

Insulflex Sdn Bhd  
Lot 6 & 8, Jalan P/1  
Kawasan Perusahaan Bangi  
43650 Bandar Baru Bangi  
Selangor Darul Ehsan  
Malaysia

**FOR**

Product: Thermal Insulation Material

Brand: INSULFLEX®

Model: INSULFLEX®

Country of Origin: Malaysia

Product Details: Thickness : 25 mm  
Density : 150 kg/m<sup>3</sup>

which has complied with the requirements of the scheme and based on the following:

## Standard(s)

British Standard 476 Part 6 : 1989 &  
Part 7 : 1997

## Test Report(s)

PSB No. 54S051241/1/OKH &  
54S051241/2/OKH  
(Rating : Class '0')

A handwritten signature in black ink, appearing to be 'Henry Heng', written over a horizontal line.

**Henry Heng**  
Chief Executive Officer

|                 |                         |                        |                 |
|-----------------|-------------------------|------------------------|-----------------|
| Certificate No: | Date of Original Issue: | Date of Last Revision: | Date of Expiry: |
| 011399          | 10/10/2005              | -                      | 31/10/2008      |



PSB TEST® \*Class 1A/1B products are entitled to use this mark on their products.

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of PSB Corporation Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the Product Listing Scheme. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested.