



No Lesen : LI009301

Licence No :

SIJIL BARANGAN TERSENARAI

Product Listing Certificate



SIRIM QAS International Sdn. Bhd. dengan ini menganugerahkan kepada
SIRIM QAS International Sdn. Bhd. hereby grants to

INSULFLEX CORPORATION SDN. BHD.
LOT 6 & 8, JALAN P/1
KAWASAN PERUSAHAAN BANGI
43650 BANDAR BARU BANGI
SELANGOR, MALAYSIA

Sijil untuk menggunakan Tanda Barangan Tersenarai
a certificate to use the Listed Product Mark on

CLOSED CELL RUBBER INSULATION MATERIALS

Please refer to detail in the SCHEDULE

sebagai mematuhi keperluan
as complying with

BS 476 : PART 6 : 1989

BS 476 : PART 7 : 1997



Mohd Azanuddin bin Salleh
Pengarah Urusan
Managing Director
SIRIM QAS International Sdn. Bhd.

SIRIM QAS International Sdn. Bhd.
(No. Syarikat 410334-X)
1, Persiaran Dato' Menteri
SekSYEN 2, Peti Surat 7035
40700 Shah Alam
Selangor Darul Ehsan
MALAYSIA.

Tel : 60-3-55446400
Faks : 60-3-55446466

<http://www.sirim.my>
<http://www.malaysian-certified.my>

Tarikh Mula Pensijilan : 30 August 2006

Certified Since

Sah Sehingga : 30 August 2018

Valid Until

Tarikh Dikeluarkan : 23 August 2017

Issue Date

No Siri : 032930

Serial No

Lesen ini dianugerahkan tertakluk kepada syarat-syarat Perjanjian Pensijilan Barangan SIRIM QAS International Sdn. Bhd.
This Licence is granted subject to the provisions of the Product Certification Agreement of SIRIM QAS International Sdn. Bhd.

SCHEDULE

INSULFLEX CORPORATION SDN. BHD.



Brand : INSULFLEX
Model : NOMINAL DENSITY: 60kg/m³
Rating : FIRE PROPAGATION INDEX, I: 2.7
SURFACE SPREAD OF FLAME: CLASS ONE
Type : SHEET & TUBE
Size : NOMINAL THICKNESS: 45mm

TEST REPORT NO. : 2017FE0056, 2017FE0057

End of page
