



PSB Singapore

CERTIFICATE OF CONFORMITY

No. CLS2 15 08 80836 001

Certificate Holder:	Insulflex Corporation Sdn. Bhd. Lot 6 & 8 Jalan P/1 Kawasan Perusahaan Bangi Bandar Baru Bangi 43650 Bangi MALAYSIA
Product:	Thermal Insulation Materials
Brand Name:	Insulflex
Model(s):	Insulflex
Product Details:	Closed Cell Nitrile Rubber Density: 100kg/m ³ Thickness: 25mm Tested on the non-printed (smooth) face (Rating: Class 0)
Standard(s):	BS 476-6:1989/A1:2009 BS 476-7:1997
Country of Origin:	Malaysia
Test Report(s):	7191119217-MEC15/1-YWA/PIC, 7191119217-MEC15/2-YWA/PIC
Issued on:	2015-09-02
Valid until:	2018-09-01

Vice-President (Certification Department)
TÜV SÜD PSB

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of TÜV SÜD PSB Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking TÜV SÜD PSB's website at www.tuv-sud-psb.sg

