



No Lesen : LI009301

Licence No :

## SIJIL BARANGAN TERSENARAI

### *Product Listing Certificate*



SIRIM

**SIRIM QAS International Sdn. Bhd.** dengan ini menganugerahkan kepada  
*SIRIM QAS International Sdn. Bhd. hereby grants to*

**INSULFLEX CORPORATION SDN. BHD.**  
**LOT 6 & 8, JALAN P/1**  
**KAWASAN PERUSAHAAN BANGI**  
**43650 BANDAR BARU BANGI**  
**SELANGOR, MALAYSIA**

**Sijil untuk menggunakan Tanda Barangan Tersenarai**  
*a certificate to use the Listed Product Mark on*

**CLOSED CELL RUBBER INSULATION MATERIALS**

**Please refer to detail in the SCHEDULE**

**sebagai mematuhi keperluan**  
*as complying with*

**BS 476 : PART 6 : 1989**

**BS 476 : PART 7 : 1997**

**Mohd Azanuddin bin Salleh**  
Ketua Pegawai Eksekutif  
*Chief Executive Officer*  
SIRIM QAS International Sdn. Bhd.

SIRIM QAS International Sdn. Bhd.  
(No. Syankat 410334-X)  
1, Persiaran Dato' Menteri  
Seksyen 2, Peti Surat 7035  
40700 Shah Alam  
Selangor Darul Ehsan  
MALAYSIA.

Tel : 60-3-55446400  
Faks : 60-3-55446466

<http://www.sirim.my>  
<http://www.malaysiancertified.com.my>

**Tarikh Mula Pensijilan : 30 August 2006**

*Certified Since*

**Sah Sehingga : 30 August 2020**

*Valid Until*

**Tarikh Dikeluarkan : 01 August 2019**

*Issue Date*

**No Siri : 048185**

*Serial No*

Lesen ini dianugerahkan tertakluk kepada syarat-syarat Perjanjian Pensijilan Barangan SIRIM QAS International Sdn. Bhd.  
*This Licence is granted subject to the provisions of the Product Certification Agreement of SIRIM QAS International Sdn. Bhd.*

## SCHEDULE

INSULFLEX CORPORATION SDN. BHD.



Trade Mark : INSULFLEX  
Model : NOMINAL DENSITY: 60kg/m<sup>3</sup>  
Rating : FIRE PROPAGATION INDEX, I: 2.7  
SURFACE SPREAD OF FLAME: CLASS ONE  
Type : SHEET & TUBE  
Size : NOMINAL THICKNESS: 45mm

TEST REPORT NO. : 2017FE0056, 2017FE0057

---

*End of page*

---