

## SIJIL BARANGAN TERSENARAI

*Product Listing Certificate*



**SIRIM QAS International Sdn. Bhd.** dengan ini menganugerahkan kepada  
*SIRIM QAS International Sdn. Bhd. hereby grants to*

**INSULFLEX CORPORATION SDN. BHD.**  
**LOT 6 & 8, JALAN P/1**  
**KAWASAN PERUSAHAAN BANGI**  
**43650 BANDAR BARU BANGI**  
**SELANGOR, MALAYSIA**

**Sijil untuk menggunakan Tanda Barangan Tersenarai**  
*a certificate to use the Listed Product Mark on*

**CLOSED CELL RUBBER INSULATION MATERIALS**

**Please refer to detail in the SCHEDULE**

**sebagai mematuhi keperluan**  
*as complying with*

**BS 476 : PART 6 : 1989**  
**BS 476 : PART 7 : 1997**



**Nur Fadhilah binti Muhammad**  
Ketua Pegawai Eksekutif  
*Chief Executive Officer*  
SIRIM QAS International Sdn. Bhd.



# SCHEDULE

**INSULFLEX CORPORATION SDN. BHD.**



Trade Mark : Company ID: INSULFLEX CORPORATION SDN. BHD.  
Model : NOMINAL DENSITY: 60kg/m<sup>3</sup>  
Rating : FIRE PROPAGATION INDEX, I: 2.7  
SURFACE SPREAD OF FLAME: CLASS ONE  
Type : SHEET & TUBE  
Size : NOMINAL THICKNESS: 45mm

Trade Mark : Company ID: INSULFLEX CORPORATION SDN. BHD.  
Model : NOMINAL DENSITY: 60 +/- 5kg/m<sup>3</sup>  
Rating : FIRE PROPAGATION INDEX, I: 7.6 SURFACE SPREAD OF FLAME: CLASS ONE  
Type : SHEET & TUBE  
Size : NOMINAL THICKNESS: 6.0mm - 25.00mm

Trade Mark : NOVACO  
Model : NOMINAL DENSITY: 60kg/m<sup>3</sup>  
Rating : FIRE PROPAGATION INDEX, I: 2.7 SURFACE SPREAD OF FLAME: CLASS ONE  
Type : SHEET & TUBE  
Size : NOMINAL THICKNESS: 45mm

Trade Mark : NOVACO  
Model : NOMINAL DENSITY: 60 +/- 5kg/m<sup>3</sup>  
Rating : FIRE PROPAGATION INDEX, I: 7.6 SURFACE SPREAD OF FLAME: CLASS ONE  
Type : SHEET & TUBE  
Size : NOMINAL THICKNESS: 6.0mm - 25.00mm

TEST REPORT NO. : 2017FE0056, 2017FE0057, 2020FE0413, 2020FE0413-S1,  
2020FE0546, 2020FE0414, 2020FE0415

**End of page**